

Severn Trent Water

REPORT TO BE SENT TO:

K T C (Edibles) Ltd
 JS House
 Moorcroft Drive
 Wednesbury
 WS10 7DE

ANALYSIS REPORT

SAMPLING POINT CODE 98203376

SAMPLE FROM: K T C (Edibles) Ltd
 JS House
 Moorcroft Drive Moorcroft Par
 Wednesbury West Midlands
 WS10 7DE

DESCRIPTION: Food Processing

SAMPLE NUMBER: 487363

SAMPLE DATE: 02/11/04

SAMPLE TIME: 09:55

CHARGEABLE: Y

SAMPLE METHOD: SPDT

SAMPLE REASON: ROUTINE

TAKEN BY : 666

DETERMINAND	RESULT VALUE	UNITS	CONSENT LIMITS	
S.S.	316	MG/L	IM 0	:1000
COD(1-HR)	4240	MG/L	IM 0	:1000 *

Analysis performed just prior to installation of Recoil Unit

SAMPLE HAS BREACHED A LIMIT

REPORT DATE: 18/11/04

ENQUIRIES REGARDING THIS REPORT SHOULD
 BE MADE TO: CATCHMENT SUPPORT
 01214523666

SIGNED: *A. Smith*

DATE: *22/11/04*

SEVERN
 TRENT
 ENVIRONMENTAL LEADERSHIP